

## Porous Pavement Checklist

**Annual inspections are required.** This checklist describes inspection activities, and notes additional recommended inspections. Contact the design engineer, Clean Water Services or City representative for more information.

✓ K C M H C	Recommended, in addition to required annual inspection	System Feature	Problem	Conditions to Check for	Preferred Conditions and Maintenance Practices
	Annually Required	Structural components	Water infiltrates unevenly across surface or ponds in low areas	Clogged surface	Water infiltrates evenly across surface; recommend vacuum sweep at least twice per year and power wash annually or as needed; do not use surfactants
	Annually Required	Structural components	Cracked or moving edge constraints; cracked or settled pavement	Cracked or moving edge constraints, or cracked or settled pavement that affects overall performance	Repair all cracks, settlement or other defects that affect performance per manufacturers' specifications
	Annually during the Fall Required	Vegetation	Leaf litter deposition on surface	Leaf litter that could affect stormwater infiltration through pavement	Sweep leaf litter and sediment to prevent surface clogging and ponding
	Annually during the growing season Required	Vegetation	Weeds	Weeds that cover 10% of the surface area	Remove weeds by hand, or use an herbicide approved for use around sensitive areas; Refer to Clean Water Services integrated pest management guidance documents.
	Annually Required	Filter medium between pavers	Aggregate loss in pavers from settling and power washing	Settling of pavers or lack of aggregate around pavers	Reset pavers and replace pore space with aggregate from original design